BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 1109

Date : 30/7/2017

1. Customer's Name and Address : BBMP ward No-2
   with Telephone No. Chowdeshwari ward-2
2. Well Location : Harohalli - Naidu Layout
3. Total Well Depth / Drilled in Ft. : 1000 Ft
4. Casing Erected in Ft. : 180 Ft
5. Water Struck at the Depth of : 250 Ft
6. Total Yield (Measuring method "V" Norch : 3" / Inches on "V" Norch)
7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Black soil
8. At the Depth of : 450 Feet
9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

ಸಮೃದ್ಧಿ

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

Smt. Kavitha Singh
Mob : 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleshwaram, Bangalore-03.

Ref. :.....

Date : 30/7/12

REPORT ON GROUND WATER INVESTIGATION

Name — B.B.M.P

Address — Ward No - 02

Location — R Harohalli Naidu Layout

Topography —

Soil Type — Black ~~Red~~ Soil

Rock Type — Ordinary.

Nos. — **RECOMMENDATIONS**

Depth — 1100 Ft

Casing — 180 Ft

Yield — 3"

Aquifers —

Remarks —

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ನಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 1108

Date : 29/7/2017

1. Customer's Name and Address with Telephone No. : B.B.M.P. ward no-02 Chowdeshwari ward-02. - -
2. Well Location : Harolalli near O.H.T. tank.
3. Total Well Depth / Drilled in Ft. : 950 Ft
4. Casing Erected in Ft. : 180 Ft
5. Water Struck at the Depth of : 750 ft
6. Total Yield (Measuring method "V" Norch : 2" 0" / Inches on "V" Norch)
7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Red Soil
8. At the Depth of : 350 Ft
9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

ಸಮೃದ್ಧಿ

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

Smt. Kavitha Singh
Mob : 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleshwaram, Bangalore-03.

Ref. :.....

Date :30/7/12

REPORT ON GROUND WATER INVESTIGATION

Name B.B.M.P

Address Ward No - 02

Location R Harohalli Naidu Layout

Topography —

Soil Type Black ~~Red~~ Soil

Rock Type Ordinary.

Nos.

RECOMMENDATIONS

Depth 1100 Ft

Casing 180 Ft

Yield 3"

Aquifers —

Remarks —

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh